

R8. 2月		越知谷配水区	根宇野配水区	粟賀配水区	大山区配水区	猪篠配水区	比延配水区	高朝田配水区	長谷配水区	上小田配水区	川水上配水区	湊配水区																																																																																				
採取日時		2月10日	2月10日	2月10日	2月10日	2月10日	2月17日	2月17日	2月17日	2月17日	2月17日	2月17日																																																																																				
気温	℃	0.0	2.0	7.0	2.0	2.0	7.0	9.0	6.0	10.0	10.0	10.0																																																																																				
水温	℃	11.0	13.5	16.0	16.0	13.0	6.0	7.0	8.0	6.0	12.0	14.0																																																																																				
一般細菌	100個/ml以下	0	0	0	0	0	1	0	0	0	0	0																																																																																				
大腸菌	検出されないこと	陰性	陰性	陰性	陰性	陰性	陰性	陰性	陰性	陰性	陰性	陰性																																																																																				
塩化物イオン	200mg/L以下	4.3	12.3	9.1	8.4	3.7	10.5	11.5	3.6	3.7	3.3	3.8																																																																																				
有機物(TOC)	3mg/L以下	0.3	0.3	0.2	0.3	0.3	0.2	0.2	0.3	0.5	0.5	0.2																																																																																				
pH値	5.8以上8.6以下	6.73	6.90	6.67	6.64	7.04	6.57	6.45	6.85	7.10	6.95	6.43																																																																																				
味	異常でないこと	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし																																																																																				
臭気	異常でないこと	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし																																																																																				
色度	5度以下	1未満	1未満	1未満	1未満	1未満	1未満	1未満	1未満	1未満	1未満	1未満																																																																																				
濁度	2度以下	0.1未満	0.1未満	0.1未満	0.1未満	0.1未満	0.1未満	0.1未満	0.1未満	0.1未満	0.1	0.1未満																																																																																				
遊離残留塩素	単位:mg/L	0.40	0.20	0.50	0.30	0.40	0.40	0.50	0.40	0.20	0.20	0.20																																																																																				
ヒ素及びその化合物	0.01mg/L以下	/								0.002																																																																																						
六価クロム化合物	0.02mg/L以下							/																																																																																								
シアン化合物及び塩化シアン	0.01未満													/						0.001未満	0.001未満	0.001未満	0.001未満	0.001未満																																																																								
塩素酸	0.6以下																			/						0.06未満	0.06未満	0.06未満	0.06未満	0.06未満																																																																		
クロロ酢酸	0.02以下																									/						0.002未満	0.002未満	0.002未満	0.002未満	0.002未満																																																												
クロロホルム	0.06以下																															/						0.001未満	0.001未満	0.002	0.004	0.005																																																						
ジクロロ酢酸	0.03以下																																					/						0.003未満	0.003未満	0.003未満	0.003	0.003																																																
ジブロモクロロメタン	0.1以下																																											/						0.001未満	0.001未満	0.001未満	0.001	0.002																																										
臭素酸	0.01以下																																																	/						0.001未満	0.001未満	0.001未満	0.001未満	0.001未満																																				
総トリハロメタン	0.1以下																																																							/						0.001未満	0.001未満	0.003	0.008	0.011																														
トリクロロ酢酸	0.03以下																																																													/						0.003未満	0.003未満	0.003未満	0.003未満	0.003未満																								
ブロモジクロロメタン	0.03以下																																																																			/						0.001未満	0.001未満	0.001	0.003	0.004																		
ブロモホルム	0.09以下																																																																									/						0.001未満	0.001未満	0.001未満	0.001未満	0.001未満												
ホルムアルデヒド	0.08以下																																																																															/						0.008未満	0.008未満	0.008未満	0.008未満	0.008未満						
アルミニウム及びその化合物	0.2mg/L以下																																																																																					/									0.02未満	